

**Regulation of energy-saving heat protection
and energy-saving installation engineering at buildings**

(2nd regulation for law amending of the energy-saving regulation – EnEV 2014)

of May 1, 2014

Legal basics:

- Guideline 1010/31EU of the European Parliament and the board of December 16, 2002 about the total energy efficiency of buildings (EPBD – Energy Performance of Buildings Directive)
- 4th law amending of the energy-saving-law of July 4, 2013
- State order Hamburg: Order to implement the laws of energy-saving of October 15, 2002

For you important quintessence of the EnEV 2014:

In article 3 „existing buildings and installations“ in § 12 the operator of inbuilt air conditioning systems with an actual power output of more than 12 kilowatt is requested to implement energetic inspections by legitimated persons.

Obligations in time flow:

The first inspection has to be implemented in the 10th year after start of operation or modernization of fundamental components.

Installations, which at 1st of October 2007 were more than four and less than 12 years old, have to come under scrutiny within six years. That is until 30th September 2013.

Installations, which at 1st of October 2007 were more than 12 years old, have to come under scrutiny within four years. That is until 30th September 2011.

Installations, which at 1st of October 2007 were more than 20 years old, have to come under scrutiny within two years. That is until 30th September 2009.

After the first inspection the installations have to be inspected continuously every 10th year at least.